

# FLANGED - BALLVALVES FIG. 92

**ANSI 150      1/2" - 6"**

**Stainless cast steel A351CF8M - Carbon cast steel A216WCB**

**Firesafe** certified acc. BS 6755 until 4"



**1/2" - 2"**




**3" - 6"**

**Cee Vee Ltd.**


Tel 01453 821666

Fax 01453822298



[www.cee-vee.co.uk](http://www.cee-vee.co.uk)




Item		Stainless steel	Carbon steel
1	Handle	304	304
1.1	Adapter	A351CF8M	A351CF8M
1.2	Sleeve	Vinyl	Vinyl
2	Stem	316	316
3	Stem nut	304	304
4	Stop plate	304	304
5	Gland flange oval	A351CF8M	A351CF8M
6	Top flange ISO 5211	A351CF8M	A216WCB
7	Belleville washers	301	301
8	Stem seal follower	316	316
9	Stem packing	Graphit	Graphit
10	Stem seal	PTFE	PTFE
11	Antistatic device on request	316	316
12	Body seal	Graphit	Graphit
13	Insert	A351CF8M	A216WCB
14	Seat	PTFE	PTFE
15	Ball	316	316
16	Body	A351CF8M	A216WCB
17	1/2"+3/4" Saddle lock	301	301
18	1/2"+3/4" Separator	301	301
19	Stop pin	316	316
20	Antistatic device on request	316	316
21	Intermediate ring	316	316



1/2" + 3/4"



3" - 6"



DN	A	B	D	E	F	ØG	H	L	M	ØN	nxd3	ØTK	wght kg	Cv	Break torques Nm
1/2"	30	14	5/16" UNF	5	135	88,9	69	108	F03	10	4x16	60,5	1.8	10	10
3/4"	31	18	3/8" UNF	6	135	98,6	77	117	F03	15	4x16	69,9	2.4	16	12
1"	35	24	3/8" UNF	6	160	108	105	127	F03	20	4x16	79,2	2.8	25	15
1 1/2"	47	28	1/2" UNF	8	180	127	110	165	F04	32	4x16	98,6	5.1	62	30
2"	57	28	5/8" UNF	10	190	152,4	110	178	F05	38	4x19	120,7	7.5	84	40
3"	102	26	22	14	480	190,5	135	203	F07	65	4x19	152,4	15.8	245	190
4"	112	26	22	14	480	228,6	145	229	F07	80	8x19	190,5	23.3	450	240
6"	117	26	30	20	480	279,4	185	254	F10	125	8x22	241,3	45.5	650	280

Cv = Volume of water in gallon/min at a pressure drop of 1 psi

## Declaration of conformity according to the attachment VII of the EC standard 97/23

The Company  
PROCOL Engineering AG  
Udermülstrasse 24  
CH-8320 Fehraltorf

Declares in fully own responsibility, that the product  
(pressure containing equipment part without mounted additional aggregates)

Fig.: **Ball Valve - Series 20, 90 92**

Quantity: see delivery note No. xxxxxx

on which this declaration refers, is in conformity with EC standard 97/23  
and has been submitted to the corresponding conformity test procedure

Fluids of group 1 Dangerous gases and Fluids if $p_s > 0.5\text{bar}$	$\leq \text{DN } 25$	DN > 25 Diagram 6, Article 3 Attachment II		
Fluids of group 2 Other gases and Fluids if $p_s > 0.5\text{bar}$	$\leq \text{DN } 32$	DN > 32, $p_s \times \text{DN} > 1000$ Diagram 7, Article 3 Attachment II		
Category	none	I	II	III
Conformity- Test procedure	-	Module A	Module A1	Module H

The surveillance is made by SVTI

Society for technical inspection  
Richtstrasse 15  
CH-8304 Wallisellen

WARRES No. R13521  
Page 2 of 13



Project: **Procol Engineering** Certificate Number: **SOU9720279/1**  
Client: **Warrington Fire Research** Office: **Crawley**  
Client's Order Number: **Test No. R13521** Date: **06/06/97**  
Order Status: **Incomplete**  
Inspection Dates: **28/04/97** Final: **28/04/97**

This certificate is issued to **Warrington Fire Research** to certify that R.D.Winstanley the undersigned surveyor to Lloyd's Register did, at their request, attend their premises at Trowers Way, Redhill, Surrey on the above date for the purpose of witnessing fire tests on the undernoted valve tested on behalf of **Procol Engineering A.G.**

**Description.**

1-Off Procol Series AF 92 Size 2" Flanged Ball Valve.  
Reduced Port ANSI 150lbs.

**Scope of Inspection**

- a. Visual examination.
- b. Witness Fire Tests No. R13521 in accordance with BS 6755: Part 2: 1987
- c. Endorse Test Results and issue Lloyd's Register Certificate.

A Fire Test in accordance with BS 6755: Part 2: 1987 was witnessed by the undersigned during which the following was observed.

THROUGH LEAKAGE DURING BURN PERIOD. 70ml  
EXTERNAL LEAKAGE Zero  
BURN PERIOD 30 mins.  
TEST PRESSURE HP 210psig 1.P 29psig

On completion of testing and cooling down the valve was visually examined and as far as could be determined found to be satisfactory and free from any significant distortion.

In view of the tests now conducted it is considered by the undersigned that the performance of the above valve has been satisfactorily demonstrated as meeting the requirements of BS 6755: Part 2: 1987 and that the results reported for Test No. R13521 are true and accurate.



R.D. Winstanley  
Senior Surveyor to Lloyd's Register.

NOTICE: This certificate is subject to the terms and conditions overlaid, which form part of this certificate.  
Lloyd's Register of Shipping, registered office: 71 Fenchurch Street, London EC3M 4BS

## TEST REPORT

TEST SPONSOR : **PROCOL ENGINEERING AG, Postfach, CH-8802 Kirschberg, Zurich, Switzerland.**

SUMMARY : A 2" Class 150 1 piece flange Ball has been subjected to a fire type-test in accordance with the method described in Appendix A of BS 6755: Part 2: 1987, to confirm the pressure-containing capability of the valve during and after the fire type test.

The valve was a 1 piece flange Ball valve Series AF92, Size 2". Reduced port ANSI 150 LBS.

A summary of the leakage rates is given in the following table:-

Leakage Rate in ml/min	Through Leakage Rate	Maximum Allowed	External Leakage Rate	Maximum Allowed
<b>Burn Period</b>	2.3	800	Zero	200
<b>Cool Down</b>				
<b>Low Hydrostatic Pressure Test</b>	Zero	80	Zero	40
<b>High Hydrostatic Pressure Test</b>			Zero	400

The valve satisfied the performance requirements specified in Clauses 6-11 of BS 6755: Part 2: 1987.

DATE OF TEST : 28 April 1997

REPORT ISSUED : 10 June 1997



# CeeVee Ltd.

Tel 01453 821666

Fax 01453 822298

www.cee-vee.co.uk